

PROVISIONS BY DTHERS

*GENERAL_
HOISTWAY MUST BE IN ACCORDANCE WITH SAFETY CODE FOR ELEVATORS (ASME A17.1 OR B44-2000) AND ALL STATE/PROVINCIAL AND LOCAL CODES.

PLIMB HISTYAY— DIE TO CLOSE RUNNING CLEARANCES INVER/AGENT MUST ENSURE THAT HIJSTVAY AND PIT (WHERE PROVIDED) ARE LEVEL, PLUMB AND SQUARE AY DARE IN ACCORDANCE WITH THE DIMENSIONS ON THESE DRAVINGS.

MINIMUM DYERHEAD CLEARANCE OWNER/AGENT MUST E ENSURE MINIMUM

CONSTRUCTION SITE— DWER/AGENT TO PROVIDE ALL MASDIARY,
CARPENTRY AND DRYVALL VIDRY AS REQUIRED AND SHALL PATCH AND
MAKE GOLD CINCLUDING FINISH PAINTING ALL AREAS WHERE
WALLS/FLORGS MAY REQUIRE TO BE CUIT, DRILLED DR ALTERED IN
ANY WAY TO PERMIT THE PROPER INSTALLATION OF THE LIFT.

DIMENSIONS
DIMENSIONS
OFNITACIOR/CUSTOMER TO VERIFY ALL DIMENSIONS AND REPORT ANY
DISCREPANCIES TO DUR OFFICE IMMEDIATELY.

ELODR/SUPPORT VALL LOADS— STRUCTURAL ENGINEER TO ASSURE THAT BUILDING AND SHAFT VILL SAFELY SUPPORT ALL LOADS IMPOSED BY THE LIFT EQUIPMENT. REFER TO THE TABLES ON THIS DRAVING FOR LOADS IMPOSED BY THE EQUIPMENT.

<u>DOORS-</u> SUITABLE LINTELS MUST BE PROVIDED BY OWNER/AGENT. DOOR FRAMES ARE NOT DESIGNED TO SUPPORT OVERHEAD WALL

*MACHINE ROOM

LOCATED AT THE LOVEST

LEVEL ADJACENT TO HOISTVAY, UNLESS SHOWN OTHERVISE ON THE

LAYOUT DRAVINGS. FIELD ADJUSTMENT BY INSTALLER MAY BE

LOCKING DOOR.

BE THROUGH A SELF CLOSING AND SELF

LOCKING DOOR. ACCESS

S.EEVES FOR DIL & ELECTRIC LINES- PROVIDED BY OTHERS, FROM MACHINE ROOM TO HOISTWAY. (POSITION PER INSTALLERS INSTRUCTIONS).

LIGHTS		ᄝ		
TS 115/1PH	230/1PH/60HTZ	R INFO 208/3PH/60HTZ	(V/PH/CYCLE)	INPUT VOLTAGE
	60	z 30	SIZE (AMPS)	DISCUNNECT
15	50	30	FUSE (AMPS)	AVTED BWIL
	21	15.6	SIZE (AMPS) FUSE (AMPS) CURRENT (AMPS)	DELAY FULL LOAD

<u>POWER SUPPLY</u>— (SEE SPECIFICATIONS) LOCKABLE FUSED DISCONNECT WITH AUXILIARY CONTACT TO BRAKE THE BATTERY FEED, OR CIRCUIT BREAKERS VITH A 3-POLE BREAKER FOR BATTERY FEED REQUIRED, IN COMPLIANCE WITH ELECTRICAL CODE, AS FOLLOWS (LOCATED ON VALL ON LOCK JAMB SIDE OF MACHINE ROOM DOOR) <u>PERMANENT POWER-</u> BEFORE INSTALLATION CAN BEGIN, PERMANENT

<u>LIGHTING-</u> DWNER/AGENT TO ENSURE AT LEAST 5 FTC OR 54 LUX AMBIENT LIGHTING OVER ELEVATOR AREA.

FASCIA PANEL BELDY UPPER LEYEL ENTRANCE: WHERE REGUIRED, FASCIA PANEL MUST BE FASTENED TO A SOLID WALL AND BE PERPENDICULAR TO THE FLOOR AND WALLS. HOISTWAY FASCIA IS NOT SELF-SUPPIRTING FOR LING, CONTINUOUS RUNS VOID OF ENTRANCES, ADEQUATE SUPPORT AND THE FASCIA MUST BE PROVIDED BY OTHERS.

RETURN WALLS- RETURN WALLS AT ENTRANCES MUST BE BUILT-N BY OTHERS AFTER ENTRANCE ASSEMBLIES ARE IN PLACE ENTRANCE ASSEMBLY MUST BE SECURELY FASTENED TO WALLS BY ELEVATOR

REV-000



8

14" ***

NOTE:

Additional pit equipment required when over 36" deep , consult yo over 36" deep , consult your dealer for details

131"(3327) 120"(3048)

ORION MODEL 4260