

OVISIONS BY OTHERS

 $\sqrt{AY}_{-}$  THE HDISTWAY MUST BE IN ACCORDANCE WITH B355 CODE FOR ELEVATORS AND ESCALATORS' (ASME A18.1) AND TEC/PROVINCIAL AND LOCAL CODES.

PLUMB HDISTWAY- DUE TO CLOSE RUNNING CLEARANCES OWNER/AGENT MUST ENSURE THAT HDISTWAY AND PIT (WHERE PROVIDED) ARE LEVEL, PLUMB AND SQUARE AND ARE IN ACCORDANCE WITH THE DIMENSIONS ON THESE DRAWINGS.

<u> DYERHEAD CLEARANCE</u> DWNER/AGENT MUST ENSURE MINIMUM D CLEARANCE IS IN COMPLIANCE WITH CODES.

CONSTRUCTION SITE- OWNER/AGENT TO PROVIDE ALL MASONRY, CARPENTRY AND DRYWALL WORK AS REQUIRED AND SHALL PATCH AND MAKE GOOD (INCLUDING FINISH PAINTING) ALL AREAS WHERE WALLS/FLOORS MAY REQUIRE TO BE CUT, DRILLED OR ALTERED IN ANY WAY TO PERMIT THE PROPER INSTALLATION OF THE LIFT.

JPPORT WALL LOADS- STRUCTURAL ENGINEER TO ASSURE LDING AND SHAFT WILL SAFELY SUPPORT ALL LOADS BY THE LIFT EQUIPMENT. REFER TO THE TABLES ON THIS FOR LOADS IMPOSED BY THE EQUIPMENT.

<u> DDRS ARE REQUIRED-</u> SUITABLE LINTELS MUST BE PROVIDED RAGENT. DOOR FRAMES ARE NOT DESIGNED TO SUPPORT

LOCATION / ACCESS- MACHINE ROOM LOCATED AT THE LOWEST LEVEL ADJACENT TO HOISTWAY, UNLESS SHOWN OTHERWISE ON THE LAYOUT DRAWINGS. FIELD ADJUSTMENT BY INSTALLER MAY BE NECESSARY TO MEET JOB SITE CONDITIONS OR REGULATIONS. ACCES MACHINE ROOM TO BE THROUGH A SELF CLOSING LOCKING DOOR.

S FOR DIL & ELECTRIC LINES- FROM MACHINE ROOM TO AS REQUIRED. (POSITION PER INSTALLERS INSTRUCTIONS).

	INPUT VOLTAGE	DISCONNECT	TIME DELAY	DELAY FULL LOAD
	(V/PH/CYCLE)	SIZE (AMPS)	FUSE (AMPS)	SIZE (AMPS)   FUSE (AMPS)   CURRENT (AMPS)
MOTOR INFO	MOTOR INFO 208/3PH/60HTZ	30	20	10.6
	230/1PH/60HTZ	60	30	17.0
CAB LIGHTS	115/1PH		15	

ORMATION IS SUBJECT TO CHANGE.

REFERENCE OUR ON-LINE DRAWINGS AT

CONSIDERATION IS SUBJECT TO CHANGE.

CONCORD.