

## Part 1- General

### 1.1 SCOPE

To furnish all labor, materials and equipment necessary or required to fully complete the installation of the elevator as indicated on the Drawings and Specifications. This suggested specification is intended to cover the complete installation of the Concord INFINITY™ SRE Standard Residential Elevator design.

### 1.2 SYSTEM DESCRIPTION

The elevator assembly shall consist of a power unit, car, guide system, 1:2 cable hydraulic lifting device, control system, signals and alarms, electrical wiring, and parts and accessories necessary to provide required performance, operation, code and safety requirements.

### 1.3 QUALITY ASSURANCE

#### 1.3.1

The elevator/lift shall meet or exceed the applicable regulations of all governing agencies and be in conformance with the applicable sections of the most current edition of the following codes and standards:

- a) ASME A17.1 “Safety Code for Elevators and Escalators; “Private Residence Elevators”.
- b) ICC/ANSI A117.1-1998 “Accessible and Usable Buildings and Facilities”.
- c) NFPA 70-1999 “The National Electric Code” (NEC).
- d) ADAAG “Americans With Disabilities Act Accessibility Guidelines” (where applicable).
- e) CSA B44.1/ASME A17.5 “Elevator and Escalator Electrical Equipment”
- f) Local codes and regulations, as applicable.

#### 1.3.2 Requirements of the Regulatory Agencies

Requirements of the Regulatory Agencies

- a) Fabricate and install work in compliance with all applicable jurisdictional authorities.
- b) File shop drawings and submissions to local authorities as the information is made available. Company pre-inspection and jurisdictional authority inspections and permits are to be made on a timely basis as required. Work will include all inspections and re-inspections that are required to ensure licenses are issued.

#### 1.3.3 Subcontractor Qualifications

- a) Execute work of this specification only by a contractor/company who has adequate product and public liability insurance in excess of one million dollars.
- b) Skilled tradesmen must be employees of the contractor and perform the work on a timely basis. Employees must be trained by the manufacturer and be supervised by the elevator contractor.

### **1.3.4 Substitutions**

No substitutions will be considered unless written request for approval has been submitted by the bidder and received by the architect at least 10 days before the receipt of bids. Each such request shall include a complete description of the proposed substitute including drawings, test data, photographs, and any other information needed for consideration.

## **Part 2- Preparatory Work by Other**

### **2.1**

The following preparatory work to accommodate/receive the elevator is to be done by others:

#### **2.1.1**

Provide power unit machine room to meet applicable Codes and Standards.

#### **2.1.2**

Permanent power (220 Volt, Single Phase, 30 Amp) to operate the elevator to be provided to a Lockable Fused/Cartridge Type Disconnect Switch with auxiliary contact/switch for emergency battery lowering. Refer to architectural drawings for permanent power specifications and location of disconnects.

#### **2.1.3**

Provide 110-volt lighting supply and disconnect. Refer to architectural drawings for permanent power specifications and location of disconnects.

#### **2.1.4**

Provide an enclosed, plumb and square hoistway with smooth interior surfaces. Include for fascias or furring of hoistway interior where applicable.

#### **2.1.5**

- a) Provide doors, frames, and door hardware.
- b) Provide rough openings as per elevator contractor's drawings.

#### **2.1.6**

Provide substantial, level pit floor slab to support loads indicated on elevator contractor's shop drawings.

#### **2.1.7**

Provide adequate support for guide rail fastenings.

**2.1.8**

Provide pit water proofing or sump pump, if required (see elevator contractor for location).

**2.1.9**

Provide 8" (203 mm) pit.

**2.1.10**

Provide 92" (2337 mm) minimum overhead (distance from floor at upper level to underside of roof).

### **Part 3- Submittals**

**3.1 SHOP DRAWINGS (presentation)**

The shop drawings shall show a complete layout of the elevator equipment detailing dimensions, clearances and location of machinery. Including the following:

- a) Drawings show the dimensions including plans, elevations, and sections to show equipment locations.
- b) Load and reaction drawings shall be provided by the elevator manufacturer and detailed on drawings.

### **Part 4- Product Data**

**4.1 MANUFACTURER/PRODUCT**

The elevator shall be the CONCORD INFINITY® SRE Standard Residential Elevator manufactured by Concord Elevator Inc. Toll Free (800) 661-5112 and (905) 791-5555, Fax 791-2222

<b>Dealer:</b>	Name _____ Number _____
<b>Rated Load:</b>	750 lbs.(340 kg.)
<b>Rated Speed:</b>	36-fpm (0.18 m/s) nominal
<b>Car Dimensions:</b>	36" W x 48" Depth (914 W x 1220 D mm)
<b>Operation:</b>	Automatic
<b>Gate Type:</b>	Horizontally collapsible, accordion style with 3 vision panels
<b>Power Supply:</b>	220 Volt, Single Phase, 30 Amps
<b>Travel Distance:</b>	50' (15.2 m) max: _____
<b>Levels Served:</b>	Maximum 4: _____
<b>Number of Openings:</b>	Two (2) Maximum
<b>Lighting Supply:</b>	110 Volt, 1 Phase, 60 Cycle, 15 Amps
<b>Jack Type:</b>	1:2 Cable Hydraulic
<b>Pump Type:</b>	Submersible with Variable Speed Valve Leveling
<b>Device Type:</b>	Magnetic

## **4.2 CAR ENCLOSURE**

### **4.2.1 WALLS**

1/2" (13 mm) Melamine panels and black anodized aluminum trim.

### **4.2.2 CEILINGS**

White melamine non-removable with four (4) recessed incandescent down lights

### **4.2.3 FLOOR**

Plywood sub-flooring.

### **4.2.4 HANDRAIL**

Black painted oak handrail located on control panel.

### **4.2.5 EMERGENCY OPERATION**

The elevator car shall be equipped with a battery-powered emergency lowering device and alarm that can be actuated on the failure of normal building power supply. Battery will be rechargeable type with an automatic recharging system.

### **4.2.6 EMERGENCY LIGHT**

The car shall be equipped with an integral emergency light that will illuminate automatically in the event of a main power failure.

### **4.2.7 CAR OPERATING PANEL**

Car operating panel shall consist of metal push buttons with halo lighting for each landing, an emergency stop button, an alarm button and a key switch. The key is removable in both the on and off position. All mounted on a #4 finished stainless steel panel. Car station panel is hinged.

### **4.2.8 CAR LIGHTING**

The car lighting shall consist of Four (4) low voltage recessed incandescent down lights. The failure of one lamp shall not cause the remaining lamp to extinguish.

### **4.2.9 AUTOMATIC LIGHTS**

Overhead lights in the car compartment shall turn ON automatically when the elevator door is opened and to stay on while the elevator is in use. The elevator lights will shut off by a timer when the elevator is not in use.

## **4.3 DOOR LOCKS**

Locks shall be electrically operated and electrically released at floor level and will remain unlocked until hall or car call is placed. When released, the locks' lag member will drop down and close the electrical circuitry to ensure the elevator cannot move unless the door is closed and locked (a true interlock).

#### **4.4 HALL CALL STATIONS**

Provide a keyless hall call station with an illuminated call button and stainless steel cover plate for each landing

#### **4.5 PLATFORM TOE GUARD**

A platform toe guard shall be provided at each car entrance opening to extend below the car entrance opening for safety.

#### **4.6 LEVELING DEVICE**

- a) The elevator shall be provided with a 2-way leveling device, which will maintain the car within 1/2" (13mm) of the landing.
- b) Leveling device sensors shall be located in a position to be inaccessible to unauthorized persons.

#### **4.7 CAR GATE**

Horizontally collapsible accordion style car gate with rattan panels and three (3) clear acrylic vision panels car gate shall enclose each car entrance.

#### **4.8 HYDRAULIC POWER UNIT**

- a) The pump and motor shall be the submersible type installed inside the oil tank.
- b) The controller shall be integrally mounted on the power unit frame and pre-wired and tested before shipment.
- c) Control circuitry to be "Programmable Logic Controls" and located at the top of the oil tank.
- d) The power unit control valve shall be a variable speed proportional valve type that includes all hydraulic control valving inherently.  
This valve shall incorporate the following features:
  - (i) Up and down acceleration and deceleration speed adjustment for smooth starts and stops.
  - (ii) Smooth stops at each landing shall be an inherent feature of the valve.
  - (iii) Adjustable pressure relief valve.
  - (iv) Manually operating DOWN valve to lower elevator in an emergency.
  - (v) Pressure gauge indicating in P.S.I. and Bars.
  - (vi) Gate valve to isolate cylinder from pump unit.
  - (vii) Negative pressure switch.

#### **4.9 CYLINDER AND PLUNGER**

##### **4.9.1**

The cylinder shall be constructed of steel pipe of a sufficient thickness and suitable safety margin. The top of the cylinder shall be equipped with a cylinder head with an internal guide ring and self-adjusting packing.

**4.9.2**

The plunger shall be constructed of a steel shaft of a proper diameter machined true and smooth. The plunger shall be provided with a stop electrically welded to the bottom to prevent the plunger from leaving the cylinder.

**4.10 CABLE**

Minimum of two 3/8" (10 mm) IWRC Galvanized Aircraft Cables.  
Minimum breaking strength of 14,400 lbs. each.

**4.11 SAFETY DEVICE**

A "slack/broken cable" safety device shall be supplied which will stop and sustain the elevator and its rated load, if either of the hoisting cables become slack or breaks. The safety device shall be re-settable by the operation of the elevator in the upward direction. A switch shall be mounted in such a position as to sense the operation of the safety device, and will open the safety circuit to the controller to prevent operation of the elevator in either direction.

**4.12 GUIDE YOKE**

The 1:2 guide yoke/sheave arrangement shall be supplied with a sheave, guide shoes, roller bearings and adjustable cable guards. The sheave shall be finished with rounded grooves to fit the cables.

**4.14 FINAL LIMIT SWITCH**

The elevator shall be equipped with a final limit switch to cut off all power to the elevator if the upper normal terminal stopping devices fail.

**4.15 GUIDE RAILS AND BRACKETS****4.15.1**

Steel 8lb/ft "T" guide rails and brackets shall be securely fastened to the building structure.

**4.15.2**

Brackets shall securely hold the guides in a plumb and true position regardless of car loading.

**4.15.3**

Guides shall be bolted through the hoistway enclosure with back-up plates, washers and nuts. Subject to architects' alterations and approval.

#### **4.16 CAR SLING**

##### **4.16.1**

Car sling shall be fabricated from steel members with adequate bracing to support the platform and cab.

##### **4.16.2**

The buffer-striking member on the underside of the car must stop the elevator before the jack plunger reaches its down limit of travel.

##### **4.16.3**

Guide shoes to be solid slipper type with polyurethane inserts.

#### **4.17 WIRING**

All wiring and electrical connections shall comply with applicable Codes, insulated wiring shall have flame retardant and moisture proof outer covering and shall be run in conduit or electrical wireways. Traveling cables shall be flexible and suitably suspended to relieve strain.

### **Part 5 - Execution**

#### **5.1 EXAMINATION**

All site dimensions shall be taken to ensure that tolerances and clearances have been maintained and meet local regulations.

#### **5.2 PREPARATION**

Pre-inspect the construction and service requirements for “Work by Others.” These requirements will be included in drawings, diagrams, engineering data sheets and special instructions before the work commences.

### **Part 6 – Warranty**

#### **6.0 WARRANTY**

Concord Elevator shall provide a Manufacturer’s limited parts warranty as outlined in Appendix A.

## **Part 7 – Owner’s Instruction & Manual**

### **7.0 OWNER’S INSTRUCTION & MANUAL**

After installation is completed, the contractor shall instruct the owner in the proper use, operation and maintenance requirements of the elevator. Instructions to also include emergency procedures and safety rules and precautions. The contractor shall also supply the owner with an Owner’s Manual detailing the operating, safety, and maintenance procedures of the elevator.



# Appendix A

## Concord Elevator Manufacturer's Limited Product Warranty

Term of warranty – this warranty is valid for a period of 36 months from the date that the product shipped from our factory. Purchase price for product must be paid in full for manufacturer to release parts under this warranty.

Coverage – this warranty applies to the repair or replacement, at Manufacturer's option, of parts that fail due to defective material or workmanship. Manufacturer may, at its option, provide factory reconditioned parts. This warranty is provided to the Authorized Concord Dealer on behalf of the final purchaser of the product and is not transferable. The Manufacturer's warranty does not cover labor charges for the removal, repair or replacement of warranty parts but such costs may be covered for a period of time by Authorized Dealer's warranty, which is provided to purchaser separately.

### Conditions:

- 1) This warranty only applies to products installed and maintained by a Concord Elevator Authorized Dealer in conformance with all applicable local and national codes.
- 2) The warranty is void if regular inspection and maintenance of product is not being carried out by an Authorized Concord Dealer in accordance with the recommendations contained in the Owner's Manual. It is the Owner's responsibility to keep records of all such service.
- 3) This warranty does not apply to the following:
  - 1) Consumable items which include: light bulbs, batteries, oil seals, mechanical switches, guide shoe inserts, drive belts, hydraulic fluids, greases, oils etc.
  - 2) Structural or cosmetic components that are subject to normal wear and tear, external forces and/or misuse. This includes metal panels, glass, plexiglass, gates, doors, buttons, switches, upholstery, trim etc
  - 3) Items that require periodic assessment, maintenance and/or replacement. This includes paint, caulking, weather seals, etc
  - 4) Malfunction or damage to product caused by accident, misuse, abuse or vandalism, lack of proper maintenance, improper installation or placement of product, neglect, improper adjustment, modification or alteration, structural condition of building or hoistway, overloading, failure to follow operating instructions or acts of God.

### Standard Procedures:

Required warranty parts will be shipped at Concord Elevator's expense by UPS ground. Expedited or air shipment of parts is available at Dealer's request and expense. Some parts covered under this warranty may be commercially available from a source close to the job site and Concord will reimburse Dealer for cost to purchase these items provided that approval is obtained from Concord's Technical Support Department in advance.

### Disclaimers:

*Concord disclaims liability for any personal injury or property damage resulting from the operation of a product that has been modified from the original Concord design. No person or company is authorized to change the design of this product without written authorization by Concord.*

*Concord's obligation under this warranty is exclusively limited to the repair or exchange of parts that fail within the applicable warranty period.*

*Concord assumes no responsibility for expenses or damages, including incidental or consequential damages. Some states and/or provinces do not allow the exclusion or limitation of incidental or consequential damages so the above limitation may not apply to you.*